



CSIR Natural Resources and the Environment

PO Box 395 Pretoria 0001 South Africa
Building 21, CSIR, Meiring Naude Rd., Pretoria
Tel +27 12 841 4279
Fax: +27 12 841 3695
Email: LSchaefer@csir.co.za

CSIR WATER LABORATORIES:

Name of Client: ICE 4 Africa
Contact Person: Jacques Maree
Address: P.O.Box 388, CRESTA, 2118
Tel: 011
Date of Analysis: 12/10/2015
Date of Issue: 12/11/2015

Analytical Report


Report No. 150071

The detection and quantification of enteric viruses involves ultra-filtration and detection by propagation in appropriate cell cultures.

Sample Name	Sample No.	Description of Sample	RESULTS
			Enteric Virus Count / 10 l
Sample 1	1	Water	0

This report relates only to the water samples actually received and tested by the CSIR Natural Resources and the Environment on 01/10/2015. The CSIR does not take any responsibility for any matters arising from further use of these results. This report shall not be reproduced except in full without written approval of the laboratory manager. All work is undertaken according to the CSIR General Conditions of contract.

Date: 12/11/2015

Gerrit Idema: 
Approved Signatory